

# Water and Wastewater Authority of Wilson County

## Gladeville Supply Water Quality Report 2006

### Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected 14 of these contaminants. We found all of these contaminants at safe levels.

### What is the source of my water?

Your water comes from two wells located near the water plant at 3826 Vesta Rd. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water supply to contamination. A well head protection plan is available for your review at the offices of the Gladeville Utility District between 8:00 A.M. and 4:30 P.M. weekdays. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Community water systems are required to disclose the detection of contaminants; however, bottled water companies are not required to comply with this regulation. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The Tennessee Dept. of Environment has prepared a Source Water Assessment Program Report for the untreated water sources. The Report assesses the susceptibility of untreated water sources to potential contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible, or slightly susceptible based on geological factors and human activities in the vicinity of the water source. Our rating is slightly susceptible. An explanation of the Tennessee Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed at [www.state.tn.us/environment/dws/dwassess.shtml](http://www.state.tn.us/environment/dws/dwassess.shtml) or you may contact the water system to obtain copies of specific assessments.

### Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Community water systems are required to disclose the detection of contaminants; however, bottled water companies are not required to comply with this regulation. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by

calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**For more information about your drinking water, please call Chris Leuber at 449-2951.**

**Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.**

### How can I get involved?

Our Water Board meets Quarterly except for special called meetings at the Water Authority office. Please feel free to participate in these meetings.

### Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. We want you to know that we pay attention to all the rules.

### Other Information

Due to all water containing dissolved contaminants, occasionally your water may exhibit slight discoloration. We strive to maintain the standards to prevent this. We at the Water and Wastewater Authority work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

### DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

# Water Quality Data

## What does this chart mean?

- **MCLG:** Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL:** Maximum Contaminant Levels are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **AL - Action Level,** or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **TT - Treatment Technique,** or a required process intended to reduce the level of a contaminant in drinking water.
- **BDL- Below Detection Limit**
- **ND- Non-Detects-**laboratory analysis indicates that the contaminant is not present.
- **mrem/yr-** Millirems per year- measure of radiation absorbed by the body.
- **MRDL-**Maximum Residential Disinfectant Level-The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial disinfectants.
- **MRDLG – Maximum residual disinfection level goal.** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Unless otherwise noted, data presented in table is from sampling performed during the 2006 calendar year by the Gladeville U.D.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria <sup>1</sup>	No	1	0	2006	0	<5% positive samples	Naturally present in the environment
Turbidity* <sup>2</sup>	No	0.18 avg.	0.05-0.24 NTU	2006	N/A	TT(95%<0.3 NTU)	Soil run-off
Copper <sup>1</sup> 0 out of 30 sites exceeded action level	No	90 <sup>th</sup> %= 0.23 ppm		2006	0	AL=1.3 ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	No	.96 ppm	.91 - .96 ppm	2006	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead <sup>1</sup> 0 out of 30 sites exceeded action level	No	90 <sup>th</sup> %= 1.4 ppb		2006	0	AL=15 ppb	Corrosion of household plumbing systems, erosion of natural deposits
TOC (Total Organic Carbon)**	No	1.3 ppm avg.	1.0 – 2.5 ppm	2006	TT	TT	Naturally present in the environment
Chlorine <sup>1</sup>	No	1.7 ppm avg.	0.8 – 2.2 ppm	2006	MRDLG 4 ppm	MRDL 4 ppm	Water additive used to control microbes
Barium	No	.035 ppm		2002	0	2.0 ppm	Erosion of natural deposits
Sulfate	No	52 ppm		2002	0	250	Erosion of natural deposits
Sodium	No	2.7 ppm		2005	N/A	N/A	Erosion of natural deposits; used in water treatment.
TTHM (Total Trihalomethanes)	No	43 ppb	20 - 57 ppb	2006	0	80 ppb	By-product of drinking water chlorination
HAA5 (Haloacetic Acids)	No	40 ppb	16 - 53 ppb	2006	0	60 ppb	By-product of drinking water chlorination
Nitrate	No	.45 ppm		2006	N/A	10 ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Radium 226	No	.50 pCi/L		2003	0	15 pCi/L	Erosion of natural deposits

<sup>1</sup>Sampling performed by the Water and Wastewater Authority of Wilson County.

<sup>2</sup> 100% of our samples were below the turbidity limit.

**\*Turbidity:** Turbidity does not present any risk to your health. We monitor turbidity which is a measure of the cloudiness of water, because it is a good indicator that our filtration system is functioning properly.

**\*\*** We met the treatment technique requirements for Total Organic Carbon.

**About the data:** Most of the data presented in this table is from testing done between Jan. 1 and Dec. 31, 2006. We monitor for some contaminants less than once per year, and for those contaminants, the date of the last sample is shown in the table.