

Water and Wastewater Authority of Wilson County

Gladeville Supply Water Quality Report 2018

Is my drinking water safe?

We have conducted numerous tests for contaminants that may be in the drinking water and our water meets all of EPA's health standards.

What is the source of my water?

Your water, which is ground water, comes from wells located near the water plant at 3826 Vesta Rd and is delivered to the Water and Wastewater Authority of Wilson County by Gladeville Utility District. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. Our source is rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <http://www.tn.gov/environment/article/wr-wq-source-water-assessment> or you may contact the Water Authority to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting chief operator James Hutchison at 615-444-2869 between 8:00 A.M. to 4:30 P.M. weekdays.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Chris Leauber at 615-449-2951.

How can I get involved?

Our Water Board meets Quarterly except for special called meetings at the Water Authority office. Please feel free to participate in these meetings.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Water Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 615-449-2951.

Water Quality Data

What does this chart mean?

- **MCLG:** Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health.
- **MCL:** Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water.
- **AL - Action Level,** or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- Parts per million (ppm) or Milligrams per liter (mg/l) – (e.g. one penny in ten thousand dollars)
- Parts per billion (ppb) – (e.g. one penny in ten million dollars)
- Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.
- Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water.
- **TT - Treatment Technique,** or a required process intended to reduce the level of a contaminant in drinking water.
- **BDL- Below Detection Limit**
- **ND- Non-Detects-**laboratory analysis indicates that the contaminant is not present.
- **MRDL-Maximum Residential Disinfectant Level-**The highest level of disinfectant allowed in drinking water.
- **MRDLG – Maximum residual disinfection level goal.** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Unless otherwise noted, data presented in table is from sampling performed during the 2018 calendar year by the Gladeville U.D.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria ^{1,2}	No	1 positive	N/A	2018	0	5% positive samples	Naturally present in the environment
Turbidity*	No	0.14 NTU	0.02–0.14 NTU	2018	N/A	TT	Soil run-off
Copper ¹ 0 out of 30 sites exceeded action level	No	90 th % = 0.148 ppm	N/A	2018	1.3 ppm	AL=1.3 ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	No	0.87 ppm avg.	0.77 – 0.94 ppm	2018	4 ppm	4 ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead ¹ 1 out of 30 sites exceeded action level	No	90 th % = 0.50 ppb	N/A	2018	0 ppb	AL=15 ppb	Corrosion of household plumbing systems, erosion of natural deposits
TOC (Total Organic Carbon) **	No	1.92 ppm avg.	1.20 – 2.73 ppm	2018	TT	TT	Naturally present in the environment
Chlorine ¹	No	1.53 ppm avg.	0.2 – 2.3 ppm	2018	MRDLG 4 ppm	MRDL 4 ppm	Water additive used to control microbes
Sodium	No	1.79 ppm	N/A	4-4-17	N/A	N/A	Erosion of natural deposits; used in water treatment.
Nitrate	No	0.30 ppm	N/A	2018	10.0 ppm	10.0 ppm	Soil run-off from fertilizer
TTHM (Total Trihalomethanes)	No	45.0 ppb	30 – 45 ppb	2018	0 ppb	80 ppb	By-product of drinking water chlorination
HAA (Haloacetic Acids)	No	53.0 ppb	32 - 53 ppb	2018	0 ppb	60 ppb	By-product of drinking water chlorination
Gross Alpha	No	2.6 pCi/L	N/A	2014	N/A	15 pCi/L	Erosion of natural deposits

Unregulated Contaminants***

Strontium	No	190 ppb	N/A	2015	N/A	N/A	Naturally present in the environment
Vanadium	No	0.40 ppb	N/A	2015	N/A	N/A	Naturally present in the environment
Chromium, Hexavalent	No	0.09 ppb	N/A	2015	N/A	N/A	Naturally present in the environment
Chlorate	No	290 ppb	N/A	2015	N/A	N/A	Naturally present in the environment

¹Sampling performed by the Water and Wastewater Authority of Wilson County.

²All repeat and additional samples were negative.

***Turbidity** is measure of the cloudiness of the water and does not present any risk to your health. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system. We met the treatment technique for turbidity with 100% of our samples being below the permitted limit of 0.3 NTU.

** We met the treatment technique requirements for Total Organic Carbon in 2018.

***Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. For additional information call the Safe Drinking Water Hotline at (800) 426-4791.

Cryptosporidium is a microbial parasite which is found in surface water and groundwater under the influence of surface water throughout the U.S. Although *Cryptosporidium* can be removed by filtration, the most commonly used filtration methods cannot guarantee 100 percent removal. Monitoring of our source water from February 2017 through January 2019 did indicate the presence of *Cryptosporidium* in 1 out of 24 samples tested. For informational purposes, please be aware that symptoms of infection by the parasite include nausea, diarrhea, and abdominal cramps. Most healthy individuals are able to overcome the disease within a few weeks. However, immuno-compromised people have more difficulty and are at greater risk of developing severe, life threatening illness. Immuno-compromised individuals are encouraged to consult their doctor regarding appropriate precautions to take to prevent infection. For more information on *Cryptosporidium*, contact the Safe Drinking Water Hotline by calling (800) 426-4791.

About the data: Most of the data presented in this table is from testing done between Jan. 1 and Dec. 31, 2018. We monitor for some contaminants less than once per year, and for those contaminants, the date of the last sample is shown in the table.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Requirements Not Met for the Gladeville Utility District, our water supplier

The Gladeville Utility District, our water supplier, violated drinking water monitoring requirements during four consecutive months beginning in October 2016 and ending in January 2017. Even though these were not emergencies, as our customers, you have a right to know what happened and what we have done to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the period of October 2016 through January 2017, we did not monitor on a schedule in accordance with the Environmental Protection Agency’s Long Term 2 Enhanced Surface Water Treatment Rule (known as LT2 sampling) which requires the District to test for *Cryptosporidium* and *e. coli* in our source water and therefore cannot be sure of the quality of your drinking water at that time.

What Should I do? There is nothing you should do at this time. The Table below lists the contaminants we did not properly test for during the specific period, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, and when samples should have been taken, and the dates or period of time when follow-up samples were taken:

Contaminant	Required Sampling Frequency	Number of Samples Taken	When Samples Should Have Been Taken	When 24 Samples Were Taken
<i>Cryptosporidium</i>	1/month for 24 consecutive months	0 in Oct. 2016 – Jan. 2017	Monthly, Oct. 2106 – Sept. 2018	Monthly, Feb. 2017 – Jan. 2019
<i>e. coli</i>	1/month for 24 consecutive months	0 in Oct. 2016 – Jan. 2017	Monthly, Oct. 2016 – Sept. 2018	Monthly, Feb. 2017 – Jan. 2019

What is being / has been done? We have since taken the required samples, beginning in February 2017 and continuing monthly through January 2019. The samples showed we have met the drinking water monitoring standards and we have now completed all the LT2 monitoring requirements and are in full compliance with the LT2 Enhanced Surface Water Treatment Rule. For more information, please contact Glenn Jordan at (615) 444-2869 or 3826 Vesta Road, Lebanon, TN 37090.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting in a public place or distributing copies by hand or mail.

This notice is being sent to you by the Water and Wastewater Authority of Wilson County as part of the 2018 Consumers Confidence Report, **State Water System ID # TN0000790**.

Date distributed: **May 2019**.