

**RESOLUTION ADOPTING A REGULATION FOR CUSTOMER SIDE POTABLE
WATER BOOSTER PUMPS**

Be it resolved by the Board of Commissioners of the Water and Wastewater Authority of Wilson County, Tennessee that the following provision is adopted as a regulation governing the provision of water services by the Authority as applicable.

“A customer may install a booster pump on the customer owned plumbing located on the customer side of the water meter. Such booster pump must be equipped with a low-pressure cut-off mechanism designed to cut off the booster pump when the pressure on the suction side of the pump drops to twenty (20) psi gauge. The operation of such booster pump must not have a negative impact on the water distribution system or create a non-compliance issue with the Rules of the Tennessee Department of Environment and Conservation, Division of Water Resources.”

This Resolution stated herein shall become effective on June 21, 2024.

Resolution Adopted: June 20, 2024.