

Water & Wastewater Authority of Wilson County, Tennessee

POLICY ON MINIMUM WATER LINE SIZE FOR ADDITIONS BY PRIVATE
OWNER AND/OR DEVELOPER

April 28, 2005

- A. The standard minimum pipe size for water line additions to the Water Authority water distribution system in connection with the proposed subdivision of property, commercial development(s), or to make public water service available to existing unserved or underserved parcels of land by private owner(s) or developer(s) shall be a nominal eight-inch (8") in diameter.
- B. Variances to the standard minimum line size may be granted by the Executive Director or on appeal of the Water Authority board when definable factors such as projected water usage, operation and maintenance costs, geographical location or physical characteristics of the proposed property to be served are such that it is in the best interest of the Water Authority's system and/or customers to do so.
- C. Water lines larger than the standard minimum may be required where justified by generally accepted engineering principals and where it is in the best interest of the Water Authority's system and/or customers to do so.